

TRIPURA GAZETTE



Published by Authority

EXTRAORDINARY ISSUE

Agartala, Thursday, November 21, 2024 A. D. Kartika 30, 1946 S. E.

PART-- I--Orders and Notifications by the Government of Tripura,
The High Court, Government Treasury etc.

**GOVERNMENT OF TRIPURA
POWER DEPARTMENT
SECRETARIAT : AGARTALA**

No.F.2(112)/Power/2019/1959-68

Dated, Agartala, the 16th November, 2024.

NOTIFICATION

In exercise of powers conferred under Section 162(1) of the Electricity Act-2003 & Regulation No. 45 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations 2023 and as mandated in the Tripura Clinical Establishments (Registration & Regulation) Rules, 2021 at item number (B) 16 in the checklist for new registration/ renewal of registration of Polyclinic/Nursing Home/Private Hospital/Laboratory/ Radiological Clinic/Pathological Collection Centre etc. under Tripura Clinical Establishment (Registration & Regulation) Act, 2018, the Governor of Tripura is pleased to notify that clearance certificate regarding soundness of Internal Electrification of building for Polyclinic / Nursing Home/ Private Hospital/Laboratory/ Radiological clinic/ Pathological collection centre etc. shall be issued by the Electrical Inspector, Power Department in the state of Tripura.

1. Information on fees, procedure and a comprehensive list of documents required for getting electrical clearance regarding soundness of Internal Electrification of the building for Polyclinic / Nursing Home/ Private Hospital/Laboratory/ Radiological clinic/ Pathological collection centre etc. shall be available in the Electrical Inspectorate and web portal of the Power Department.
2. The application for electrical clearance shall be disposed of within 15 days a stipulated time.
3. The Electrical Inspector may require certain tests to be carried out during inspection of internal electrification at the clinical establishment.
4. Fees for inspection of internal electrification is set against estimation.
5. The validity of clearance certificate regarding soundness of Internal Electrification of the building shall not exceed five years.
6. Fresh application shall be made for renewal of clearance certificate regarding soundness of Internal Electrification of the building of the Clinical Establishment, and inspection of internal electrification at the clinical establishment shall be carried out as required.

By Order of the Governor


(Udayan Sinha)

Additional Secretary to the
Government of Tripura.